



COMMONWEALTH of VIRGINIA

DEPARTMENT OF ENVIRONMENTAL QUALITY

PIEDMONT REGIONAL OFFICE

Preston Bryant
Secretary of Natural Resources

4949-A Cox Road, Glen Allen, Virginia 23060
(804) 527-5020 Fax (804) 527-5106
www.deq.virginia.gov

David K. Paylor
Director

March 17, 2009

Ms. Jean Cobb
Assistant Director
Children's Home of Virginia Baptists, Inc.
6900 Hickory Road
Petersburg, VA 23803

**CERTIFIED MAIL
RETURN RECEIPT REQUESTED**

RE: Reissuance of VPDES Permit No. VA0027561, Children's Home of Virginia Baptists, Inc.

Dear Ms. Cobb:

Your VPDES permit is enclosed. A Discharge Monitoring Report (DMR) form is included with the permit. Please make additional copies of the DMR for future use. The first DMR required by this permit for monthly monitored parameters is due on May 10, 2009 for the monitoring period of April 2009. If you still have DMR data to report as required by the previous permit please submit it as an attachment to the first DMR required by this permit. Monitoring results on the DMRs should be reported to the same number of significant digits as are included in the permit limit for the parameter. Please send DMRs to:

Virginia Department of Environmental Quality
Piedmont Regional Office
4949-A Cox Road
Glen Allen, VA 23060

Note that DEQ has launched an e-DMR program that allows you to submit the effluent data electronically. If you are interested in participating in this program please visit the following website for details:

<http://www.deq.virginia.gov/water/edmrfaq.html>

As provided by Rule 2A:2 of the Supreme Court of Virginia, you have thirty days from the date of service (the date you actually received this decision or the date it was mailed to you, whichever occurred first) within which to appeal this decision by filing a notice of appeal in accordance with the Rules of the Supreme Court of Virginia with the Director,

Department of Environmental Quality. In the event that this decision is served on you by mail, three days are added to that period.

Alternatively, any owner under §§ 62.1 - 44.16, 62.1 - 44.17, and 62.1 - 44.19 of the State Water Control Law aggrieved by any action of the State Water Control Board taken without a formal hearing, or by inaction of the Board, may demand in writing a formal hearing of such owner's grievance, provided a petition requesting such hearing is filed with the Board. Said petition must meet the requirements set forth in 9 VAC 25-230-130B of Procedural Rule No. 1. In cases involving actions of the Board, such petition must be filed within thirty days after notice of such action is mailed to such owner by certified mail.

If you have any questions about the permit, please call Ms. Jaime Bauer at (804) 527-5015.

Sincerely,

A handwritten signature in black ink, appearing to read 'Curtis J. Linderman', written over a horizontal line.

Curtis J. Linderman, P.E.
Water Permit Manager

Enclosure: Permit No. VA0027561

cc: OWPP
EPA, Region III-3WP12



MEMORANDUM
DEPARTMENT OF ENVIRONMENTAL QUALITY
Piedmont Regional Office

4949-A Cox Road, Glen Allen, Virginia 23060-6295

804/527-5020

SUBJECT: Re-issuance of VPDES Permit No. VA0027561 for Children's Home of Virginia Baptists, Inc.

TO: Curtis J. Linderman, P.E., Water Permits Manager

FROM: Jaime L. Bauer, Environmental Specialist II

DATE: March 16, 2009

COPIES: PRO, OWPS, EPA

Legal Name of Owner: Children's Home of Virginia Baptists, Inc.

Application Submitted By: Ms. Jean Cobb, Assistant Director

Application Date: The issuance application was received on August 13, 2008. The date of complete application was January 14, 2009.

Type of Discharge: Existing municipal wastewater discharge.

Wastewater Treatment Facilities The treatment facilities include a stabilization lagoon.

Receiving Stream:

STREAM:	Unnamed Tributary of Church Branch
RIVER BASIN:	Appomattox
RIVER SUBBASIN:	NA
SECTION:	5c
CLASS:	III
SPECIAL STANDARDS:	None

Public Notice: The application and draft permit were given public notice according to the Permit Regulation and no comments were received.

Planning: The facility is in conformance with existing planning documents for the area.

EPA Comments: EPA has waived the right to comment on the draft permit.

VDH Comments: VDH reviewed the draft permit and commented that the raw water intake for Virginia American Hopewell water treatment plant is located on the Appomattox River approximately 16.5 miles downstream of the discharge point. They expressed no objections to this draft permit.

Previous Board Action: None.

Staff Comments: The discharge is not controversial.
The facility has paid all required maintenance fees.
The staff believes that the attached effluent limits will maintain the Water Quality Standards adopted by the Board
The permit expired on October 15, 2008. The permit reissuance did not occur prior to expiration due to an incomplete and late application submitted by the permittee.

Basis for Effluent Limits: The proposed effluent limitations are based on Water Quality Standards, Federal Effluent Guidelines, and best professional judgment.

Licensed Operator Requirements A Class IV licensed operator is required for this facility upon upgrade of the treatment systems.

Staff Recommendations:

The staff recommends that the following:

1. Approve the attached effluent limits and monitoring requirements.
2. Re-issue VPDES Permit No. VA0027561.

APPROVED:


Water Permits Manager

DATE:

3/17/09